



说明:

1. 本图单位以毫米计;
2. 本图闸门并适用范围为管径DN=50~200管道, 阀井内径1200、井深1300, ϕ 600铸铁井盖;
3. 支墩必须托住阀体, 四周用M10水泥砂浆抹八字填实.
4. GB盖板厚160mm, 做法详见苏S01-2021-39; 底板厚200mm, 做法详见苏S01-2021-35~36.
5. 采用铸铁爬梯, 安装尺寸详见苏S01-2021-372.